



Iss.	
Date	
Modification	
Ckd.	Appd.

BEKA associates
Hitchin
England
company confidential, copyright reserved.

Iss.	1
Date	21.09 2023
Modification	P0182. New drawing.
Ckd.	
Appd.	




VIEW ON ARROW A
(REAR PANEL DETAILS)




TERMINAL CONNECTIONS:

OPTION TERMINALS (WHEN OPTION FITTED):



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE FITTED OVER THE 4 STUDS & THE WING NUTS TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MIN.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)
- 4 FINALLY, FIT A SILICONE RUBBER CAP TO THE END OF EACH M3 THREADED ROD.



Title CUSTOMER DRAWING for
BA327SE 5 DIGIT I.S. INDICATOR
IN PANEL MOUNTING ENCLOSURE

Drawn	Checked	Scale
KB		NTS
Drawing No. CD327SE		