



Iss.	Date	Modification	Ckd.	Appd.
Iss.	Date	Modification	Ckd.	Appd.
Iss.	Date	Modification	Ckd.	Appd.
<div>BEKA associates Hitchin England company confidential, copyright reserved.</div>				
Iss.	Date	Modification	Ckd.	Appd.



THIRD ANGLE PROJECTION

DIMENSIONS IN mm

DO NOT SCALE



DISPLAY
(TYPICAL DISPLAY
ONLY SHOWN)

TOUGHENED
GLASS WINDOW

6 PUSH
BUTTONS

STATIC
DISSIPATIVE
MODIFIED
PPO BEZEL


NEOPRENE
GASKET

ALUMINIUM
ENCLOSURE

PRODUCT
LABEL

VIEW ON ARROW A
(REAR PANEL DETAILS)



SERIAL No.
(& TAG LEGEND IF FITTED)



4 SCREW CLAMPS

REMOVABLE
TERMINAL BLOCKS

TERMINAL CONNECTIONS:



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL.
- 3 MAXIMUM RECOMMENDED TIGHTENING TORQUE 22cNm (1.95lbf.in)

PANEL CUTOUT:

DIN 43 700: $138^{+1.0}_{-0}$ x $68^{+0.7}_{-0}$
FOR IP65: $136^{+0.5}_{-0}$ x $66.2^{+0.5}_{-0}$

Title

**CERTIFIED CUSTOMER DRAWING for
BA688CF FIELD BUS DISPLAY
IN PANEL MOUNTING ENCLOSURE**

Drawn

RC

Checked

Scale

NTS

Drawing No.

Sheet 1 of 2

Iss.	Date	Modification	Ckd.	Appd.	<div>BEKA associates Hitchin England company confidential, copyright reserved.</div>					Iss.	Date	Modification	Ckd.	Appd.
.										

