




Iss.	Date	Modification	Ckd.	Appd.	<div><div>BEKA</div><div>associates</div><div>Hitchin England</div><div>company confidential, copyright reserved.</div></div>
1	23.05 2017	New Drawing	.	.	
Iss.	Date	Modification	Ckd.	Appd.	




#### VIEW ON ARROW A (REAR PANEL DETAILS)



#### TERMINAL CONNECTIONS:



#### OPTION TERMINALS (WHEN OPTION FITTED):



#### INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL. RECOMMENDED TORQUE 22cNm MAX.
- 3 FOR PANELS GREATER THAN 3mm THICK ADD ADDITIONAL DEPTH FOR CLAMPS. (ie ADD PANEL THICKNESS LESS 3mm)

#### PANEL CUTOUT:

$$\text{DIN 43 700: } 92^{+0.8}_{-0} \times 45^{+0.6}_{-0}$$

$$\text{FOR IP66: } 90^{+0.5}_{-0} \times 43.5^{+0.5}_{-0}$$

Title

CUSTOMER DRAWING for BA317E  
1 INPUT TACHOMETER  
IN PANEL MOUNTING ENCLOSURE

Drawn

RC

Checked

.

Scale

N/A

Drawing No.

CD317E