



| | | | | | | | | | |
|---|---|------|---|--------------|---|------|--|-------|--|
| Iss. | 1 | Date | . | Modification | . | Ckd. | | Appd. | |
| Iss. | | Date | | Modification | | Ckd. | | Appd. | |
| <div><div>BEKA</div><div>associates</div><div>Hitchin</div><div>England</div><div>company confidential, copyright reserved.</div></div> | | | | | | | | | |
| Iss. | | Date | | Modification | | Ckd. | | Appd. | |




THIRD ANGLE PROJECTION

DIMENSIONS IN mm


DO NOT SCALE



VIEW ON ARROW A
(REAR PANEL DETAILS)




REMOVABLE
TERMINAL BLOCK
4 SCREW
CLAMPS
SEE NOTE 3



TERMINAL CONNECTIONS:

TERMINALS 2 & 4 ARE INTERNALLY
LINKED FOR JOINING RETURN WIRES



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL.
- 3 MAXIMUM RECOMMENDED TIGHTENING TORQUE 22cNm (1.95lbf.in)

PANEL CUTOUT:

DIN PANEL CUT-OUT: $138^{+1.0}_{-0}$ x $45^{+0.6}_{-0}$

FOR IP65: $136^{+0.5}_{-0}$ x $43.5^{+0.5}_{-0}$

Title CERTIFIED CUSTOMER DRAWING for
COMBINED I.S. INDICATOR
BA326C IN PANEL MOUNTING ENCLOSURE

| | | |
|--------------------|----------------|---------------------|
| Drawn RH | Checked | Scale NTS |
| Drawing No. | | |

| | | | | | | | | | | |
|------|------|--------------|------|-------|--|------|------|--------------|------|-------|
| Iss. | Date | Modification | Ckd. | Appd. | <div><div>BEKA</div><div>associates</div><div>Hitchin England</div><div>company confidential, copyright reserved.</div></div> | Iss. | Date | Modification | Ckd. | Appd. |
| 1 | . | . | | | | | | | | |
| | | | | | | | | | | |

