




Iss.	Date	Modification	Appd.
1	.	.	
Iss.	Date	Modification	Appd.
BEKA associates Hitchin England company confidential, copyright reserved.			
Iss.	Date	Modification	Appd.
Ckd.			
Ckd.			

THIRD ANGLE PROJECTION

DIMENSIONS IN mm DO NOT SCALE




VIEW ON ARROW A
(REAR PANEL DETAILS)



TERMINAL CONNECTIONS:

TERMINALS 2 & 4 ARE INTERNALLY LINKED FOR JOINING RETURN WIRES



INSTALLATION:

- 1 INSERT UNIT INTO PANEL CUTOUT FROM FRONT.
- 2 SCREW CLAMPS ARE CLIPPED TO THE INDICATOR & TIGHTENED FROM REAR OF PANEL.
- 3 MAXIMUM RECOMMENDED TIGHTENING TORQUE 22cNm (1.95lbf.in)

PANEL CUTOUT:

DIN PANEL CUT-OUT: $138^{+1.0}_{-0} \times 45^{+0.6}_{-0}$


FOR IP65: $136^{+0.5}_{-0} \times 43.5^{+0.5}_{-0}$

Title CERTIFIED CUSTOMER DRAWING for
 COMBINED INDICATOR
 BA526C IN PANEL MOUNTING ENCLOSURE


Drawn RH	Checked	Scale NTS
Drawing No.		

Iss.	Date	Modification	Ckd.	Appd.	Iss.	Date	Modification	Ckd.	Appd.
1	.	.							

BEKA associates
 Hitchin
 England
 company confidential, copyright reserved.



BA526C
 INDICATOR



TYPICAL APPLICATION OF BA526C

Title CERTIFIED CUSTOMER DRAWING for
 COMBINED INDICATOR
 BA526C IN PANEL MOUNTING ENCLOSURE

Drawn RH	Checked	Scale NTS
Drawing No.		