



SCHEDULE

EU TYPE EXAMINATION CERTIFICATE NUMBER: ITS09ATEX26155X R.1

13. DESCRIPTION OF THE EQUIPMENT OR PROTECTIVE SYSTEM

BA474D Indicating Temperature Transmitter is a field mounted loop powered equipment designed to display temperature in a hazardous process area and to transmit a linearised 4/20 mA current to the non-hazardous area. It provides galvanic isolation between the input and output connections.

The BA474D Indicating Temperature Transmitter may optionally be situated in the non-hazardous area as the associated electrical apparatus and provide galvanic isolation between the non-intrinsically safe area input terminals and the intrinsically safe output terminals.

The BA474D may optionally be fitted with an Alarm board.

The BA474D may additionally be fitted with an optional Back Light board.

The BA474D Indicating Temperature Transmitter comprises a field terminal board PC159, a main display board, PC157 and optional Alarm board, PC62, and/or Back Light board, PC161 all housed within a plastic, glass reinforced polyester enclosure.

The BA474D utilizes the following terminals:

4/20 mA loop powered input terminals, TB2, which will also power the optional backlight circuit. A link is provided if the backlight circuit is not used.

The sensor input terminals, TB1.

The optional Alarm Interface input terminals, TB3.

The input and output parameters at the BA474D terminals for external connections are:

Terminals TB2- 5 & 6		Terminals TB3 8 & 9; 10 & 11	
The equivalent parameters are:		The equivalent parameters are:	
Ui = 28 V	Ci = 46.42 nF	Ui = 30 V	Ci = 0.02 µF
Ii = 200 mA	Li = 0.01 mH	Ii = 200 mA	Li = 0.01 mH
Pi = 0.85 W	Co = 36.58 nF	Pi = 0.85 W	Co = 46 nF
	Lo = 0.69 mH	Uo = 0.7 V	Lo = 0.69 mH
		Io = 1.3 µA	
		Po = 4.0 µW	
Terminals TB1- 1, 2, 3 & 4			
The equivalent parameters are:			
Ui = 6 V	Ci = 16.16 µF		
Ii = 100mA	Li = 0		
Pi = 194 mW	Co = 23.84 µF		
Uo = 6 V	Lo = 3 mH		
Io = 30.3 mA			
Po = 46 mW			

BA474D, as an associated electrical apparatus, the input and output parameters are:

Terminals TB2- 5 & 6; TB3- 8 & 9; 10 & 11		Terminals TB1- 1, 2, 3 & 4	
Um = 250 V		The equivalent parameters are:	
		Ui = 6 V	Ci = 16.16 µF
		Ii = 100mA	Li = 0
		Pi = 194 mW	Co = 23.84 µF
		Uo = 6 V	Lo = 3 mH
		Io = 30.3 mA	
		Po = 46 mW	

CE Marking shall be accompanied by the identification number of the Notified Body responsible for surveillance of production.



SCHEDULE

EU TYPE EXAMINATION CERTIFICATE NUMBER: ITS09ATEX26155X R.1

14. DRAWINGS AND DOCUMENTS

TITLE	DOCUMENT Nr	LEVEL	DATE
*ATEX & IECEx Certification Information for BA474D & BA478C Indicating Temperature Transmitters Sheets 1-24, 26-28	CI470-01 (27 Sheets)	4	April 2022

Note: An * is included before the title of documents that are new or revised.
Copies of the above listed documents are kept at Intertek Italia S.p.A. archive.

15. SPECIFIC CONDITIONS OF USE

The BA474D Indicating Temperature Transmitter when installed in Zone 0 potentially explosive atmosphere shall be installed such that even in the event of rare incidents, an ignition source due to impact or friction between aluminium marking label and iron/steel is excluded.

16. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

The relevant Essential Health and Safety Requirements have been identified and assessed in Intertek Report Nr. 104596361LHD-004 dated 20th May 2022.

17. ROUTINE (FACTORY) TESTS

The voltages applied to infallible transformers shall conform to the values given in Table 10 as per the requirements of EN 60079-11:2012 Clause 11.2, Routine tests for infallible transformers.

18. DETAIL OF CERTIFICATE CHANGES

R.0 (13th January 2022):

This variation comprises the following changes to the equipment:

- Update product standards EN 60079-0 & EN 60079-11 to latest revision.
- Introduction of alternative components for obsolete optocouplers.
- EN 60079-26 :2007, EN 61241-0:2006 and EN 61241-11:2006 has been removed from the certificate listing. All requirements are considered to be covered by latest editions of EN 60079-0 & EN 60079-11.
- Initial release by Intertek Italia S.p.A. NB 2575 based on the assessment performed January through October 2021 and on the certificate legal ownership transferred from Intertek Testing & Certification Ltd. (NB 0359); the same issued original certificate number is used.

R.1 (5th July 2022):

This variation comprises the following changes to the equipment:

- Revision to opto-isolator assembly.