



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

BA405C Setpoint Display

IS / I / 1 / ABCD / T4 Ta = 60°C – CI405-27; Entity; IP65

NI / I / 2 / ABCD / T4 Ta = 60°C – CI405-27; NIFW; IP65

Intrinsic Safety Parameters

Input Parameters

Terminals	Ui (V)	Ii (mA)	Pi (W)	Ci (μF)	Li (mH)
1 & 3; 1 & 2; 1 & 13	30	200	0.85	0.04	0.01
12 & 13	28	159	0.8	0.03	0.01

Output Parameters

Terminals	Uo (V)	Io (mA)	Po (W)	Co (μF)	Lo (mH)
3 & 4	30	200	0.85	0.026	0.99

a = Parameter not affecting safety.

Special conditions of use

1. To maintain the IP65 enclosure rating the BA405C shall be installed in accordance with the mounting conditions provided on drawing number CI405-27.
2. The BA405C shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
3. The BA405C shall be protected from direct exposure to sunlight.

Equipment Ratings:

Intrinsically safe for Class I Division 1 Groups A, B, C and D and Class I Zone 1 Group IIC Hazardous (Classified) Locations using the Entity Concept when installed in accordance with Control Drawing CI405-27



Member of the FM Global Group

Nonincendive for Class I Division 2 Groups A, B, C and D and Class I Zone 2 Group IIC Hazardous (Classified) Locations using the nonincendive field wiring concept when installed in accordance with Control Drawing CI405-27.

FM Approved for:

BEKA associates
Hitchin, Hertfordshire SG5 2DA, United Kingdom



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2010
Class 3611	2004
Class 3810	2005
IEC 60529	1991


Original Project ID: 3026081

Approval Granted: January 19, 2007


Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
101217	March 16, 2011		

FM Approvals LLC



Timothy J. Adam
Technical Team Manager



Date

INTRINSICALLY SAFE INSTALLATIONS	
Appd.	
Ckd.	
Modification	
Date	
Iss.	
BEKA associates Hitchin England <small>company confidential, copyright reserved.</small>	
Appd.	
Ckd.	
Modification	
Date	
Iss.	
Date	10.01 2006
Iss.	1
HAZARDOUS (CLASSIFIED) LOCATION LOCATION: Class I, Division 1, Groups A, B, C & D	
BA405C Entity Parameters Terminals 1 & 3; 1 & 2 $U_i = 30V$ $I_i = 200mA$ $P_i = 0.85W$ $C_i = 0.04\mu F$ $L_i = 0.01mH$ Terminals 3 & 4 $U_o = 30V$ $I_o = 200mA$ $P_o = 0.85W$ $C_o = 0.26\mu F$ $L_o = 0.99mH$ Terminals 12 & 13 $U_i = 28V$ $I_i = 159mA$ $P_i = 0.8W$ $C_i = 0.03\mu F$ $L_i = 0.01mH$	
BA405C Entity Parameters Terminals 1 & 13; 12 & 13 $U_i = 30V$ $I_i = 200mA$ $P_i = 0.85W$ $C_i = 0.04\mu F$ $L_i = 0.01mH$ Terminals 3 & 4 $U_o = 30V$ $I_o = 200mA$ $P_o = 0.85W$ $C_o = 0.26\mu F$ $L_o = 0.99mH$	
Notes: 1. The associated intrinsically safe barriers or galvanic isolators must be FM approved and the manufacturers' installation drawings must be followed when installing this equipment. 2. The unclassified location equipment connected to the associated intrinsically safe barriers or galvanic isolators must not use or generate more than 250V rms or 250V dc.	<div style="border: 1px dashed black; padding: 5px;"> Note: No modification to be made without reference/approval from FM Approvals and BEKA Associates Design Department. </div>
Title FM Control Drawing for BA405C	
Drawn RC	Checked
Scale N/A	
Drawing No. Sheet 1 of 4 CI405-27	

NONINCENDIVE INSTALLATIONS			
HAZARDOUS (CLASSIFIED) LOCATION		UNCLASSIFIED LOCATION	
LOCATION: Class I, Division 2, Groups A, B, C & D			
BA405C Terminals 1, 2, 3 & 4 $V_{max} = 32V$ $C_i = 0.04\mu F$ $L_i = 0.01mH$ Terminals 12 & 13 $V_{max} = 32V$ $C_i = 0.03\mu F$ $L_i = 0.01mH$			
BA405C Terminals 1, 2, 3, 4, 12 & 13 $V_{max} = 32V$ $C_i = 0.04\mu F$ $L_i = 0.01mH$			

BEKA associates
Hitchin England
company confidential, copyright reserved.


Iss.	Date	Modification	Ckd.	Appd.
1	10.01 2006	First release		

Title

FM Control Drawing for BA405C

Drawn RC	Checked 	Scale N/A
Drawing No. Sheet 3 of 4 CI405-27		

Iss.	Date	Modification	Ckd.	Appd.
1	10.01 2006	First release		



BEKA associates
Hitchin England

company confidential, copyright reserved.

8. The BA405C is FM Approved as Nonincendive Field Wiring Apparatus for Class I, Division 2, Groups A, B, C and D Hazardous (Classified) locations without connection to associated protective barriers or galvanic isolators when installed per the National Electrical Code ANSI/NFPA 70.
9. Nonincendive field wiring installations shall be in accordance with the National Electrical Code ANSI/NFPA 70. The Nonincendive Field Wiring concept allows interconnection of Nonincendive Field Wiring Apparatus with Associated Nonincendive Field Wiring Apparatus using any of the wiring methods permitted for unclassified locations.
10. Hazardous location equipment must be FM Approved Nonincendive Field Wiring Apparatus or simple apparatus, as defined in ANSI/NFPA 70.
11. Associated apparatus shall be FM Approved Associated Nonincendive Field Wiring Apparatus installed in the unclassified location with parameters complying with the following requirements, or FM Approved Nonincendive Field Wiring Apparatus with nonincendive field wiring output(s) installed in the classified location complying with the following requirements:


Voc	equal to or less than	Vmax
La	equal to or greater than	Lcable + Li
Ca	equal to or greater than	Ccable + Ci

12. Associated apparatus shall be FM Approved Associated Nonincendive Field Wiring Apparatus installed in the unclassified location with parameters complying with the following requirements, or FM Approved Nonincendive Field Wiring Apparatus with nonincendive field wiring output(s) installed in the classified location complying with the following requirements:

Voc	equal to or less than	The lowest Vmax of the FM Approved apparatus installed in the respective loop.
La	equal to or greater than	Sum of the cable inductances and internal inductances Li of each FM Approved apparatus installed in the respective loop.
Ca	equal to or greater than	Sum of the cable capacitance and the internal capacitance Ci of each FM Approved apparatus in the respective loop.

Title

FM Control Drawing for BA405C

Drawn RC	Checked 	Scale N/A
Drawing No. Sheet 4 of 4		CI405-27