



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEX Scheme visit www.iecex.com

Certificate No.: **IECEX CML 20.0080X** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2020-06-12

Applicant: **BEKA Associates Limited**
Old Charlton Road
Hitchin
Herts
SG5 2DA
United Kingdom

Equipment: **BA212 and BA2x3 Power Isolators**

Optional accessory:

Type of Protection: **Intrinsic safety**

Marking: [Ex ia Ga] IIC
-40°C ≤ Ta ≤ +70°C

Approved for issue on behalf of the IECEX
Certification Body:

A Snowdon MIET

Position:

Assistant Certification Manager

Signature:
(for printed version)

A Snowdon

Date:

June 12, 2020

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Eurofins E&E CML Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX CML 20.0080X**

Page 2 of 3

Date of issue: 2020-06-12

Issue No: 0

Manufacturer: **BEKA Associates Limited**
Old Charlton Road
Hitchin
Herts
SG5 2DA
United Kingdom

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[GB/CML/ExTR20.0105/00](#)

Quality Assessment Report:

[GB/ITS/QAR06.0002/07](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 20.0080X**

Page 3 of 3

Date of issue: 2020-06-12

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The BA212 and BA2x3 Power Isolators are associated apparatus for installation in the safe area. The BA212 provides a single isolated intrinsically safe output. The BA2x3 provides between 1 and 4 isolated intrinsically safe outputs (x = number of outputs). The outputs are suitable for routing into hazardous areas requiring EPL Ga.

See Annex for full description and Conditions of Manufacture.

SPECIFIC CONDITIONS OF USE: YES as shown below:

See Annex for Specific Conditions of Use.

Annex:

[IECEX CML 20.0080X Annex Issue 0.pdf](#)

Annexe to: IECEx CML 20.0080X Issue 0
Applicant: BEKA Associates Ltd.
Apparatus: BA212 and BA2x3 Power Isolators



Description

The BA212 and BA2x3 Power Isolators are associated apparatus for installation in the safe area. The BA212 provides a single isolated intrinsically safe output. The BA2x3 provides between 1 and 4 isolated intrinsically safe outputs (x = number of outputs). The outputs are suitable for routing into hazardous areas requiring EPL Ga.

Intrinsic safety is achieved by limiting the energy available to the hazardous area.

The equipment has the following safety description:

BA212	BA2x3 (parameters for each output)
Um = 30V	Um = 30V
Uo = 12.4V	Uo = 12.4V
Io = 2.66A	Io = 0.67A
Po = 5.2W	Po = 1.36W

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the load connected to the output terminals shall not exceed the following values:

BA212				
Group	Capacitance (μF)	Inductance (μH)	or	L/R Ratio (μH/Ohm)
IIC	1.24	5		4.3
IIB	7.9	20		17
IIA	30.0	40		34

BA2x3 (for each output)				
Group	Capacitance (μF)	Inductance (μH)	or	L/R Ratio (μH/Ohm)
IIC	1.24	79		17
IIB	7.9	317		68
IIA	30.0	634		137

The above load parameters apply where either

- The external circuit contains no combined lumped inductance L_i and capacitance C_i greater than 1% of the above values, or
- The inductance and capacitance are distributed as in a cable, or
- The external circuit contains either only lumped inductance or lumped capacitance in combination with a cable.

Unit 1, Newport Business Park
 New Port Road
 Ellesmere Port
 CH65 4LZ

T +44 (0) 151 559 1160
E info@cmllex.com

www.cmllex.com

Company Reg No. 8554022 VAT No. GB163023642





In all other situations e.g. if the external circuit contains combined lumped inductance and lumped capacitance, up to 50% of each of the L and C values is allowed. The reduced capacitance of the external circuit (including cable) shall not be greater than 1 μ F for Groups IIA and IIB, or greater than 600nF for Group IIC.

Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- ii. The BA2x3 shall be subjected to a routine isolation test between each intrinsically safe output using a test voltage of 600Vrms for a duration of at least 1 second.

Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. The equipment shall only be powered from a supply with a maximum output voltage of 30V and which complies with one of the following:
 - Is a SELV or PELV system
 - A safety isolating transformer complying with the requirements of IEC 61558-2-6 or technically equivalent standard
 - Apparatus complying with the IEC 60950 series, IEC 61010-1, or a technically equivalent standard
 - Fed directly from cells or batteries