

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

BA307Cabc - 4/20 mA Loop Powered 3 1/2 Digit Indicator

IS / I / 1 / ABCD / T4 Ta = 60°C - Cl300-22; Entity; Type 4* $NI/I/2/ABCD/T4Ta = 60^{\circ}C$; Type 4*

*Front panel only.

Entity parameters

| Terminals | VMax | | PMax | Ci | Li | |
|--|------|------|------|------|------|--|
| and a statement of the state of the statement of the stat | (V) | (mA) | (W) | (µF) | (mH) | |
| 1, 2, 3 and 4 | 32 | 200 | 1.2 | 0.02 | 0.01 | |
| 12 and 13 | 32 | 159 | 1.2 | 0.03 | 0.01 | |

- a = Display at 0 mA: XXXX.
- b = Display at 20 mA: XXXX (with decimal point position and polarity).
- c = Accessories: backlight, root extractor or calibrator, scale card, tag strip.

Special Conditions of Use:

- 1. To maintain the Type 4 enclosure rating the BA307C shall be installed in accordance with the mounting conditions provided on drawing numbers Cl300-32.
- 2. The BA307C shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 3. The BA307C shall be protected from direct exposure to sunlight.

BA308Cabc - 4/20 mA Loop Powered 3 1/2 Digit Indicator IS / I / 1 / ABCD / T4 Ta = 60°C - Cl300-22; Entity; Type 4*

NI / I / 2 / ABCD / T4 Ta = 60°C; Type 4*

*Front panel only **Entity parameters**



| Terminals | VMax | IMax | PMax | Ci | Li |
|---|------|------|------|------|------|
| тере оны по или, постнет 4 годе выдоблене одгостили не многовического вы ны | | (mA) | (W) | (µF) | (mH) |
| 1, 2, 3 and 4 | 32 | 200 | 1.2 | 0.02 | 0.01 |
| 12 and 13 | 32 | 159 | 1.2 | 0.03 | 0.01 |

a = Display at 0 mA: XXXX.

b = Display at 20 mA: XXXX (with decimal point position and polarity).

c = Accessories: root extractor or calibrator, scale card, tag strip.

Special Conditions of Use:

- 1. To maintain the Type 4 enclosure rating the BA308C shall be installed in accordance with the mounting conditions provided on drawing numbers Cl300-32.
- 2. The BA308C shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 3. The BA308C shall be protected from direct exposure to sunlight.

BA327Cabcd - 4/20 mA Loop Powered 4 1/2 Digit Indicator

IS / I / 1 / ABCD / T4 Ta = 60°C - Cl320-22; Entity; Type 4*

NI / I / 2 / ABCD / T4 Ta = 60°C; Type 4*

*Front panel only.

Entity parameters

| Terminals | VMax | IMax | PMax | Ci | | |
|--|------|------|------|------|------|--|
| And a shopping of a straight page of a straight of the straigh | (V) | (mA) | (W) | (µF) | (mH) | |
| 1, 2, 3 and 4 | 32 | 200 | 1.2 | 0.02 | 0.01 | |
| 12 and 13 | 32 | 159 | 1.2 | 0.03 | 0.01 | |
| 8 and 9;10 and 11 | 32 | 159 | 1.2 | 0.04 | 0.02 | |

- a = Display mode: linear or root extracting.
- b = Display at 0 mA: XXXX.
- c = Display at 20 mA: XXXX (with decimal point position and polarity).
- d = Accessories: backlight, alarms, tare function, lineariser, scale card, tag strip.

Special Conditions of Use:

- 1. To maintain the Type 4 enclosure rating the BA327C shall be installed in accordance with the mounting conditions provided on drawing numbers Cl320-22.
- 2. The BA327C shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 3. The BA327C shall be protected from direct exposure to sunlight.

BA328Cabcd - 4/20 mA Loop Powered 4 1/2 Digit Indicator

IS / I / 1 / ABCD / T4 Ta = 60°C - Cl320-22; Entity; Type 4*

NI / I / 2 / ABCD / T4 Ta = 60°C; Type 4*

*Front panel only.

Entity parameters

| Terminals | VMax | lMax | PMax | Ci | Li |
|--|------|------|------|------|------|
| ting in 1944 and The area to the area and the contribution of all the contribution of the contribution | (V) | (mA) | (W) | (µF) | (mH) |
| 1, 2, 3 and 4 | 32 | 200 | 1.2 | 0.02 | 0.01 |
| 12 and 13 | 32 | 159 | 1.2 | 0.03 | 0.01 |
| 8 and 9;10 and 11 | 32 | 159 | 1.2 | 0.04 | 0.02 |



- a = Display mode: linear or root extracting.
- b = Display at 0 mA: XXXX.
- c = Display at 20 mA: XXXX (with decimal point position and polarity).
- d = Accessories: alarms, tare function, lineariser, scale card, tag strip.

Special Conditions of Use:

- 1. To maintain the Type 4 enclosure rating the BA328C shall be installed in accordance with the mounting conditions provided on drawing numbers Cl320-22.
- 2. The BA328C shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.
- 3. The BA328C shall be protected from direct exposure to sunlight.

Equipment Ratings:

BA307C & BA308C

Intrinsically safe for Class I, Division 1, groups A, B, C and D in accordance with the Entity Concept and when installed in accordance with Control Drawing Cl300-22. Nonincendive for Class I, Division 2, Groups A, B, C, and D. Indoor Hazardous Locations; Temperature ClassT4 Ambient Temperature +60°C

BA327C & BA328C

Intrinsically safe for Class I, Division 1, groups A, B, C and D in accordance with the Entity Concept and when installed in accordance with Control Drawing Cl320-22. Nonincendive for Class I, Division 2, Groups A, B, C, and D. Indoor Hazardous Locations; Temperature ClassT4 Ambient Temperature +60°C

FM Approved for:

BEKA associates Hitchin, Hertfordshire, SG5 2DY, United Kingdom



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

| C22.2 No 157 | 1992 |
|------------------|------|
| C22.2 No. 1010.1 | 1992 |
| C22.2 No. 25 | 2004 |
| C22.2 No. 213 | 2004 |
| C22.2 No. 94.02 | 2007 |

Original Project ID: 4B3A7.AX

Canadian Project ID: 3032632

Approval Granted: December 16, 2008

Subsequent Revision Reports / Date Approval Amended

Report Number

Date

Report Number

Date


FM Approvals LLC

James E. Marquedant

Group Manager, Electrical

16 Decomber 2008

Date



| .1 | Т | N | | | | | ····· | · · · · · · · · · · · · · · · · · · · | | | | | |
|--------------|--------------------------------|--|---|------------|--------------------------------|----------------|----------------------------|---------------------------------------|---|--|--------------|--|--|
| Appd. | | Notes: | | | | | | | | | | | |
| Ckd. | | man For | 1. The associated intrinsically safe barriers or galvanic isolators must be FM approved and the manufacturers' installation drawings must be followed when installing this equipment. For BA327C and BA328C installations in Canada, the associated intrinsically safe barriers and galvanic isolators shall be cFM or CSA approved and the manufacturers' installation drawings shall be followed when installing the equipment. | | | | | | | | | | |
| | | shal | ll be followed | d when ins | talling the equ | iipment. | | | | | | | |
| | | The unclassified location equipment connected to the associated intrinsically safe barriers or galvanic isolators must not use or generate more than 250V rms or 250V dc. | | | | | | | | | | | |
| tion | | Installation shall be in accordance with ANSI/ISA RP 12.06.01 "Installation of Intrinsically Safe Systems for Hazardous (Classified) Locations" and the National Electrical Code ANSI/NFPA 70. BA327C and BA328C installations in Canada shall be in accordance with the Canadian | | | | | | | | | | | |
| Modification | | | Electrical Code C22.2. | | | | | | | | | | |
| Date Moc | | | | | channel of a plying with th | | | | | or | | | |
| å | +- | | Voc | or Vt | equal to or le | ss than | | Vmax | | | | | |
| lss. | | | Isc or Po | | equal to or le | | | lmax Pmax | | | | | |
| | | | La | | equal to or g | | | Lcable + | Li | | | | |
| 60 | _; | | Ca | | equal to or gr | eater tha | an | Ccable + | Ci | | | | |
| iate | reserved | | 5. One single channel or one channel of a dual channel barrier or galvanic isolator with entity parameters complying with the following requirements: | | | | | | | | | | |
| associat | England copyright reserved. | CAUTION: THESE REQUIREMENTS MUST BE FOLLOWED FOR NEW INSTALLATIONS OR MODIFICATIONS TO EXISTING INSTALLATIONS. | | | | | | | | | | | |
| | litchin iy confidential, | | Voc or Vt | equ | al to or less th | nan | or for E Canad | BA327C & la, the cF | BA328C ins M or CSA Ap | | | | |
| | HII company | | isc or it | equ | al to or less th | nan | or for l | BA327C & la, the cF | of the FMR(BA328C ins M or CSA Apied in the res | tallations in | • | | |
| . Appd. | | | Ро | equa | l to or less tha | an | or for I | BA327C & | x of the FMR BA328C ins or CSA Ap | | , | | |
| . ckd. | | | | | | | appara | atus in the | respective lo | oop. | | | |
| 328 Class | added. 528C | | La | equa | I to or greater | than | and th FMRC installa | e internal Approved ations in C | cable inducta inductance L d, or for BA32 anada, the catus installed | i of each 27C & BA328 cFM or CSA | вс | | |
| 8 37 200 | ' | | | | | | | respective | | | | | |
| o | requirements BA327C & BA | Ca equal to or greater than The sum of the cable capacitance and the internal capacitance Ci of each FMRC Approved, or for BA327C & BA328C installations in Capacitan at the cable capacitance and the internal capacitance is capacitance. | | | | | | | | | | | |
| Modi Redo | for E | | | | | | | | | espective loo | | | |
| Date 26.05 | | Title | 0 : | | D17010 | 7070 | | 7000 | Drawn RC | Checked | Scale N/A | | |
| lss. 3 | 4 | FM | Control D | rawing f | or BA324C | , <i>5</i> 2/C | and | 328C | Drawing No Sheet 2 of | 3 CI32 | 20-22 | | |

| Appd. | | | 6. | Hazardous (classified) loca | ition equipme | nt may be simple apparatu | s or FMRC A | pproved, | | | |
|--------------|----------------------|--|-------|--|---------------------------------|---|----------------|-----------------|-------------|--|--|
| Ckd. | | | | or for BA327C & BA328C i with entity parameters mee | | canada, cFM or CSA Approved equipment irements of note 5. | | | | | |
| | | | | The BA324C is FMRC App Groups A, B, C, D, E, F & 6 associated protective barric Electrical Code (ANSI/NFP | ut connectior per the Nation | | | | | | |
| Modification | | The BA327C and BA328C are FMRC and cFM Approved as nonincendive for Class I, Division Groups A, B, C & D and for Class I, Division 2, Group IIC Hazardous (classified) locations without connection to associated protective barriers or galvanic isolators when installed per the National Electrical Code (ANSI/NFPA 70) or for installations in Canada in accordance with the Canadian Electrical Code C22.2 and the voltages do not exceed 32V dc. | | | | | | | | | |
| Modi | | | 8. | When mounting BA327C | and BA328C | in an enclosure to mainta | ain Type 4 fro | nt panel rati | ng: | | |
| Date | | | | Minimum panel thickness | should be | 2mm (0.08inches) Steel 3mm (0.12inches) Alumi | | | | | |
| lss. | | | | Outside panel finish shou build-up around cut-out. | d be smooth | , free from particle inclusion | ons, runs or | | | | |
| | <u> </u> | reserved. | | Panel cut-out should be | BA327C | 43.5 x 90.0mm -0.00 + (1.71 x 3.54 inches -0.0 | | | | | |
| 301 | associat Fingland | copyright res | | | BA328C | 66.2 x 136.0mm -0.0 +0 (2.60 x 5.35 inches -0.0 | | | | | |
| | S S | 8 | | Edges of panel cut-out sh | ould be debu | rred and clean | | | | | |
| | | ential, | | Each panel mounting clip | should be tig | hened to between: 20 a | and 22cNm (| 1.77 to 1.95 | inLb) | | |
| | | confidential, | | Note: BA328C requires | four panel cli | ps. | | | | | |
| | | , Si | | | | | | | | | |
| (0) | | compo | | | | | | | | | |
| _ | | | | | | | | | | | |
| Appd | ٠ | | | | | | | • | | | |
| Ckd. | ٠ | | | | | | | | | | |
| | _ | | | | | | | | | | |
| | Class d | d. | | | | | | | | | |
| | | added. 328C | | | | | | | | | |
| | _ | irements 7C & BA | | | | | | | | | |
| ation | ı. BA327 options | ロンショ | | | | | | | | | |
| Modification | Redawn. II & III | cFM req for BA32 | | · | | | | | | | |
| Date N | 26.05 R 2005 II | | Title | | | | Drawn | Checked | Scale | | |
| Γ. | 3 26 | 4 01/ | | FM Control Drawing | for BA3240 | C, 327C and 328C | RC Drawing No. | I %∕ '- ∩I30 | N/A 0-22 | | |
| Iss | | | | ` | | <u> </u> | Sheet 3 of | 3 UIU | | | |