



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: issue No.:

Status:

Date of Issue: Page 1 of 4

Applicant: **BEKA**
Old Charlton Road
Hitchin SG5 2DD
United Kingdom

Electrical Apparatus: **Robust 105-60mm Panel Enclosure**
Optional accessory:

Type of Protection: "p", "e", "nA", "ta"

Marking: **IECEX ITS 14.0007U**
Ex e IIC Gb, Ex p IIC Gb, Ex nA IIC Gc, Ex ta IIIC Da

Approved for issue on behalf of the IECEx Certification Body: **V K Varma**

Position: Certification Officer

Signature:
(for printed version)

Vijay K. Varma
2014-06-10

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

Intertek Testing & Certification Limited
ITS House, Cleeve Road,
Leatherhead,
Surrey, KT22 7SB
United Kingdom





IECEx Certificate of Conformity

Certificate No.: IECEx ITS 14.0007U

Date of Issue: 2014-06-10

Issue No.: 0

Page 2 of 4

Manufacturer: **BEKA**
Old Charlton Road
Hitchin SG5 2DD
United Kingdom

Additional Manufacturing location
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-15 : 2010 Edition: 4	Explosive atmospheres - Part 15: Equipment protection by type of protection "n"
IEC 60079-2 : 2007-02 Edition: 5	Explosive Atmospheres - Part 2 Equipment protection by pressurized enclosure "p"
IEC 60079-31 : 2008 Edition: 1	Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'
IEC 60079-7 : 2006-07 Edition: 4	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:
GB/ITS/ExTR14.0024/00

Quality Assessment Report:
GB/ITS/QAR06.0002/03



IECEx Certificate of Conformity

Certificate No.: IECEx ITS 14.0007U

Date of Issue: 2014-06-10

Issue No.: 0

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The BEKA 105 x 60 robust panel enclosure is an empty enclosure made from stainless steel.

Enclosure comprises main enclosure casting with 10mm thick toughened glass and rubber silicon keypad buttons located on the front and four screws on the back of the enclosure for installation of the rear panel and further mounting purposes. Silicone rubber gasket providing degree of protection IP66 is retained to the surface of the front bezel. Enclosures were tested to meet the requirements of IP66 requirements for the front of the enclosure in accordance with IEC 60529.

Enclosures are provided with external earthing stud suitable for earthing wire. There are no openings in the front of the enclosure.

CONDITIONS OF CERTIFICATION: NO

--



IECEx Certificate of Conformity

Certificate No.: IECEx ITS 14.0007U

Date of Issue: 2014-06-10

Issue No.: 0

Page 4 of 4

Additional information:

Schedule of Limitation

- For an Ex nA instrument installed in an Ex n or Ex e panel enclosure, the instrument must be powered from an energy-limited circuit. The equipment is allowed to be installed in Zone 2 hazardous location.
- For an Ex nA instrument installed in an Ex px, py or pz panel enclosure, the instrument must be powered from the energy-limited circuit, and the rear panel must provide appropriate vents dependent on the characteristics of the gas used for the pressurised system. The equipment is allowed to be installed in Zone 2 hazardous location.
- For an Ex i instrument installed in an Ex px or py panel enclosure, the instrument must be powered via appropriately rated Zener barrier or galvanic isolator located in a safe area, and the rear panel must provide appropriate vents dependent on the characteristics of the gas used for the pressurised system. The equipment is allowed to be installed in Zone 1 or Zone 2 hazardous location.
- For an Ex i instrument installed in an Ex e panel enclosure, the instrument must be powered via appropriately rated Zener barrier or galvanic isolator located in a safe area. The equipment is allowed to be installed in Zone 1 or Zone 2 hazardous locations dependant on the intrinsically safe level of protection.
- For Ex nA instrument installed in Ex tc panel enclosure the instrument must be powered from the limited energy circuit, so that instrument push button contacts are nonincendive (Ex ic).
- For the Ex i instrument installed in Ex ta or Ex tb panel enclosure the instrument must be powered via appropriately rated Zener barrier or galvanic isolator located in a safe area, so that instrument push button contacts are nonincendive (Ex ia).
- The supply circuit for instruments used in the equipment with pressurized type of protection shall be rated for a prospective short circuit current of not more than 10kA.
- Final assembly must be reassessed to the relevant standards taking into consideration all types of protection used.
- Service temperature range specified by manufacturer is -40°C to +70°C.