

UK Type Examination Certificate CML 21UKEX21242X Issue 0

United Kingdom Conformity Assessment

- 1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended) – Schedule 3A, Part 1
- 2 Equipment **BA3701 DI Module Totaliser Counter**
- 3 Manufacturer **BEKA associates Ltd**
- 4 Address **Old Charlton Road, Hitchin, Herts.
SG5 2DA, UK**

5 The equipment is specified in the description of this certificate and the documents to which it refers.

6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, Approved Body Number 2503, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.

7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section 14.


8 This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN 60079-11:2012

10 The equipment shall be marked with the following:



Ex ia IIC T4 Ga

Ex ia IIIC T226°C Da

-40°C ≤ Ta ≤ +65°C



CML 21UKEX21242X
Issue 0

11 Description

The BA3701 DI Module Totaliser Counter is an intrinsically safe module intended for use with the Pageant system. The module comprises circuit boards mounted within a non-metallic enclosure with a single card edge connector for plugging into separately certified equipment (e.g. the Pageant Display unit).

The equipment also carries terminal blocks for the connection to external digital inputs and outputs. The inputs may be configured by the user as a voltage pulse input or as a voltage free contact / 2-wire NAMUR compliant sensor input.

Intrinsic safety is achieved by limiting energy storage and discharge, and by connecting to other equipment via intrinsically safe interface devices. The equipment has the following parameters:

Barrier Power in PL3 Terminals 1 - 4	3V3 supply and data PL3 Terminals 21 - 40	TB1 – TB2																											
		Pulse outputs Terminals 5-6 (values are for each output)	Digital Inputs Voltage pulse Terminals 2 - 4 (values are for each input)	Digital Inputs Voltage free contact or 2-wire sensor (Terminals 1-2 linked) Terminals 2 - 4 (values are for each input)																									
U _i = 12.4V	U _i = 4.1V	U _i = 28V	U _i = 28V	U _i = 0																									
I _i = 2.68A		I _i = 200mA	I _i = 200mA																										
P _i = 5.44W		P _i = 0.66W	P _i = 0.84W																										
	U _o = 0	U _o = 0	U _o = 1.15V	U _o = 8.8V																									
	I _o = 0	I _o = 0	I _o = 0	I _o = 7.4mA																									
	P _o = 0	P _o = 0	P _o = 0	P _o = 16mW																									
C _i = 0	C _i = 0	C _i = 0	C _i = 1.1nF	C _i = 1.1nF																									
L _i = 0	L _i = 0	L _i = 0	L _i = 4μH	L _i = 4μH																									
			<table border="1"> <thead> <tr> <th></th> <th>Co =</th> </tr> </thead> <tbody> <tr> <td>IIA</td> <td>1000μF</td> </tr> <tr> <td>IIB</td> <td>1000μF</td> </tr> <tr> <td>IIC</td> <td>100μF</td> </tr> <tr> <td>III</td> <td>1000μF</td> </tr> </tbody> </table>		Co =	IIA	1000μF	IIB	1000μF	IIC	100μF	III	1000μF	<table border="1"> <thead> <tr> <th>See Note 1</th> <th>Co =</th> <th>Lo =</th> </tr> </thead> <tbody> <tr> <td>IIA</td> <td>730μF</td> <td>4.4H</td> </tr> <tr> <td>IIB</td> <td>46μF</td> <td>2.2H</td> </tr> <tr> <td>IIC</td> <td>5.5μF</td> <td>556mH</td> </tr> <tr> <td>III</td> <td>46μF</td> <td>2.2H</td> </tr> </tbody> </table>	See Note 1	Co =	Lo =	IIA	730μF	4.4H	IIB	46μF	2.2H	IIC	5.5μF	556mH	III	46μF	2.2H
	Co =																												
IIA	1000μF																												
IIB	1000μF																												
IIC	100μF																												
III	1000μF																												
See Note 1	Co =	Lo =																											
IIA	730μF	4.4H																											
IIB	46μF	2.2H																											
IIC	5.5μF	556mH																											
III	46μF	2.2H																											

NOTE 1 - The above load parameters apply when one of the two conditions below are met:

- the total L_i of the external circuit (excluding the cable) is < 1% of the L_o value or
- the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.

If neither of the above conditions are met, the load parameters are both reduced by 50%. Additionally, the reduced capacitance of the external circuit (including cable) shall not be greater than 1μF for Groups IIA, IIB, and III, and 600nF for Group IIC.



CML 21UKEX21242X
Issue 0

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	09 Nov 2021	R14715A/00	Issue of prime certificate

Note: Drawings that describe the equipment are listed in the Annex.

13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- ii. The manufacturer shall ensure that sufficient documentation is provided with the equipment pertaining to the architecture and design of the BEKA Pageant System, to permit the user to make the necessary intrinsically safe system calculations and documentation.

14 Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. Under certain extreme circumstances, the non-metallic parts incorporated in the enclosure of this equipment may generate an ignition-capable level of electrostatic charge. Therefore, the equipment shall not be installed in a location where the external conditions are conducive to the build-up of electrostatic charge on such surfaces. In addition, the equipment shall only be cleaned with a damp cloth.
- ii. In installations requiring EPL Da, Db, or Dc, the equipment shall be within an enclosure which provides a minimum degree of protection of IP5X and which meets the requirements of EN 60079-0 Clause 8.4 (material composition requirements for metallic enclosures for Group III) and/or EN60079-0 Clause 7.4.3 (Avoidance of a build-up of electrostatic charge for Group III) as appropriate.

All cable entries into the equipment shall be made via cable glands which provide a minimum degree of protection of IP5X.
- iii. This equipment shall only be used as part of a BEKA Pageant System.

Certificate Annex

Certificate Number CML 21UKEX21242X
Equipment BA3701 DI Module Totaliser Counter
Manufacturer BEKA associates Ltd



The following documents describe the equipment defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
CI3701-01	1 to 26	1	09 Nov 2021	ATEX & IECEx Certification Information for BEKA BA3701 Digital Input Module Totaliser Counter